



Certificate

Indoor Air Comfort Gold

Knauf Insulation Virgin Blowing Wool

Product

Knauf Insulation GmbH, Am Bahnhof 7, 97346 Iphofen, Germany

Manufacturer

The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 3.1 (2011). This includes a VOC emission chamber test and an audit of the manufacturing site.

Successful evaluation means:

- No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France.
- Formaldehyde was below the limit value of 10 µg/m³.
- Sum of VOC (TVOC) was below the limit values of 1.000 µg/m³ after 3 days and 100 µg/m³ after 28 days. The product was classified A+ according to French VOC regulation.
- Sum of SVOC after 28 days was below the limit value of 20 µg/m³.
- Evaluation of individual VOC: R values were below the limit values of 1 for both German NIK and French LCI lists after 28 days. Sums of VOC without German NIK and French LCI both were below 50 µg/m³.
- Quality management system and factory production control program at production sites complied with the requirements.
- Therefore the product qualifies for the Indoor Air Comfort Gold label.

Certificate No.: 2012-IACG-033

Date: 01/04/2012

Validity of certificate: 01/04/2017

Director Certification Chemical Safety

General Manager

Eurofins Product Testing A/S
Tel. +45 70 22 42 76

ProductTesting@eurofins.com
www.product-testing.eurofins.com

Sampling, testing and evaluation were performed according to the standards ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.